

ACSPR-RPC1-(1509)(2009)(K) APPLICATION NOTE:

One or more separate RPC units can be controlled by the front panel switch and/or remote switches (if used) by connecting the RPC switch terminals to the "ON Indicator" and "Com" terminals as shown below. If desired, the separate RPC unit(s) can be switched "off" when the rack mount unit is "on" and vice-versa by connecting the switch terminal to the "OFF Indicator" terminal.

